

ASME expansion tanks

WHY AN EXPANSION TANK?

An expansion tank is required in a closed loop heating or chilled water HVAC system for two very important reasons:

1. **To control the systems operating pressure range;**
2. **To give the expanded water in the system a place to go as the water is heated. In a heating system this occurs when the system is heated from its coldest fill temperature to operation temperature. In a chilled water system this expansion occurs when the system is shut down and the system temperature rises from operating to ambient.**

The goal in sizing any expansion tank is to make the system able to accommodate the expansion of the system water throughout the heating or cooling cycles without allowing the system to exceed the pressure limits of the lowest pressure rated component in that system. The lowest rated component in most systems is, by design, the pressure relief valve. The maximum system pressure is normally set at 90% of the pressure relief valve rating at its point of installation.

BLADDER OR DIAPHRAGM TANKS COMPARED TO PLAIN STEEL TANKS

The plain steel expansion tank has been used for many years, and, in some systems, has worked very well. Using a plain steel expansion tank makes the system an air control system. One must control the air volume or air cushion above the water level of the tank. The common interface between this air cushion and the water in the tank allows the air to be absorbed by the water. If the air is not removed properly from the water and placed back into the air cushion, the expansion tank will become waterlogged.

A waterlogged tank is an expansion tank that no longer has an air cushion large enough to allow all the expanded water from the system to enter the tank without exceeding the maximum system pressure. When this occurs, the safety relief valve will open and heated system water will be discharged to the drain.

CAUTION: An expansion tank does not need to be 100% full to be waterlogged. The same symptoms will also show if the expansion tank is sized too small.

The advantage of a plain steel tank is that the initial purchase cost is lower than a diaphragm/bladder tank, but in many cases the operation costs will offset this advantage.

The bladder / diaphragm expansion tank has been developed to allow the system's air cushion to be separated from the system's water. No waterlogging of the tank can occur as the air is held between the tank wall and the exterior of a bladder placed inside the tank, while the system water is contained inside the bladder. This changes the system to an air elimination system, as any air extracted from the system water is passed out of the system into the atmosphere.

The bladder tank is usually smaller than a plain steel tank for the same application as they are precharged with air to the system operating pressure before the system is filled with water. The only water that needs to be accommodated by a bladder/diaphragm tank is the expanded water. In a heating system, this occurs when the water is heated from the fill temperature to the operating temperature. In a chilled water system the water temperature rises from operating temperature to ambient temperature. The air elimination system allows the air vent and air separator to be placed at the most advantageous point in the system for air removal, usually at the system's high point where the pressure is the lowest or at the boiler outlet where the water temperature is the highest. The expansion tank can now be placed at floor level, since air no longer needs to be returned to the tank. The diaphragm/bladder tank can also be placed at the most advantageous point in the system.

TYPICAL POSITIONING OF AN EXPANSION TANK

The system connection of an expansion is known as "The Point of No Pressure Change". This means that wherever the expansion tank is connected to the system, the pressure will always be the same as the pressure inside the tank. This is true if the tank is a plain steel or bladder/diaphragm type. This is also true whether the system pump is on or off. This pressure is only changed as water or air are added to or removed from the tank. To better understand this "Point of No Pressure Change", an in-depth study of Boyle's Law is necessary.

Because of this "Point of No Pressure Change", the system sees a pump additive pressure from the pump discharge to the expansion tank connection. From the expansion tank connection back to the pump suction, the system receives a negative pressure change from the tank pressure, due to the friction loss when there is flow.

With this loss of pressure added by the pump and the loss due to flow, it is usually better to place the "Point of No Pressure Change" or expansion tank system connection as close to the pump suction as possible.

SIZING GUIDE



Plain steel expansion tanks / Plain steel – NA Series

Job Name: _____

Date: _____

Job Location: _____

Model #: _____

Contact Name: _____

Date submitted: _____

Engineer: _____

Approved by: _____

Contractor: _____

Date of approval: _____

INFORMATION REQUIRED

1. Total system water content (1) _____ gal _____ L
2. Temperature of water when system is filled (2) _____ °F _____ °C
3. Maximum operating temperature (3) _____ °F _____ °C
4. Minimum operating pressure (typically fill pressure) (4) _____ psi _____ kPa
5. Maximum operating pressure (10% below relief valve) (5) _____ psi _____ kPa

SIZING FOR HYDRONIC HEATING/COOLING SYSTEMS

6. Enter total system water content from line (1). (6) _____ gal _____ L
7. Using the Expansion Factors table (see page 21), find and enter the expansion factor. (7) _____
8. Multiply line (6) by line (7). Enter expanded water volume. (8) _____ gal _____ L
9. Determine the acceptance factor by $(P_a \div P_f) (P_a \div P_o)$, where P_a = Pressure (atmospheric)
 P_f = Pressure at fill (atmospheric)
 P_o = Pressure at operation (atmospheric)
and enter the result. (9) _____
10. Divide line (8) by line (9) and enter tank size. (10) _____ gal _____ L

MODEL SELECTION

Select plain steel tank from NA section (see page 15).

Model _____ NA _____

CAUTION: The expansion chart is for water only. Add 60% to the expansion factors for 50/50 glycol/water solutions or contact your local Calefactio representative for other concentrations.

CONVERSION



Converting plain steel tanks to diaphragm expansion tanks

Job Name: _____

Date: _____

Job Location: _____

Model #: _____

Contact Name: _____

Date submitted: _____

Engineer: _____

Approved by: _____

Contractor: _____

Date of approval: _____

INFORMATION REQUIRED

1. Determine plain steel tanks volume (table 2, p. 22) (1) _____ gal _____ L
2. Temperature of water when system is filled (2) _____ °F _____ °C
3. Maximum operating temperature (3) _____ °F _____ °C
4. Minimum operating pressure (usually fill pressure) (4) _____ psi _____ kPa
5. Maximum operating pressure (10% below relief valve) (5) _____ psi _____ kPa

SIZING FOR HYDRONIC HEATING/COOLING SYSTEMS

6. Determine the acceptance by $(P_a + P_f) (P_a + P_o)$,
where P_a = Pressure (atmospheric)
 P_f = Pressure at fill (atmospheric)
 P_o = Pressure at operation (atmospheric)
and enter the result. (6) _____
7. Enter volume of plain steel tank
line (1). (7) _____ gal _____ L
8. Calculate expanded water volume.
Multiply line (6) by line (7) and enter. (8) _____ gal _____ L
9. Using Acceptance Factors table (see pages 23 and 24),
and enter the acceptance factor. (9) _____
10. Divide line (8) by line (9),
enter tank volume required. (10) _____ gal _____ L

Line (8) _____, expanded water (acceptance volume)
Line (10) _____, total tank volume

MODEL SELECTION

- Select expansion tank model from fixed/replaceable bladder section.
- HGT (non-code) or OT models must satisfy both lines (8) and (10).
 - AL models are selected by total volume only from line (10).

For large systems, multiple tanks can be manifolded together.

CAUTION: The expansion chart is for water only. Add 60% to the expansion factors for 50/50 glycol/water solutions or contact your local Calefactio representative for other concentrations.

EXPANSION FACTORS TABLE



Final temp.		Initial temperature												
°F	°C	40°F 4.4°C	45°F 7.2°C	50°F 10°C	55°F 12.7°C	60°F 15.5°C	65°F 18.3°C	70°F 21.1°C	75°F 23.8°C	80°F 26.6°C	85°F 29.4°C	90°F 32.2°C	95°F 35°C	100°F 37.7°C
50	10	0.00008	0.00006	-										
55	12.7	0.00027	0.00025	0.00019	-									
60	15.5	0.00057	0.00055	0.00049	0.00030	-								
65	18.3	0.00095	0.00093	0.00087	0.00068	0.00038	-							
70	21.1	0.00151	0.00149	0.00143	0.00124	0.00094	0.00056	-						
75	23.8	0.00194	0.00194	0.00188	0.00169	0.00139	0.00101	0.00045	-					
80	26.6	0.00260	0.00260	0.00254	0.00235	0.00205	0.00167	0.00111	0.00066	-				
85	29.4	0.00326	0.00326	0.00320	0.00301	0.00271	0.00233	0.00177	0.00132	0.00066	-			
90	32.2	0.00405	0.00405	0.00399	0.00380	0.00350	0.00312	0.00256	0.00211	0.00145	0.00079	-		
95	35	0.00485	0.00485	0.00479	0.00460	0.00430	0.00392	0.00336	0.00291	0.00225	0.00159	0.00080	-	
100	37.7	0.00577	0.00575	0.00569	0.00550	0.00520	0.00482	0.00426	0.00381	0.00315	0.00249	0.00170	0.00090	-
105	40.5	0.00673	0.00671	0.00665	0.00646	0.00616	0.00578	0.00522	0.00477	0.00411	0.00345	0.00266	0.00186	0.00096
110	43.3	0.00773	0.00771	0.00765	0.00746	0.00716	0.00678	0.00622	0.00577	0.00511	0.00445	0.00366	0.00286	0.00196
115	46.1	0.00881	0.00879	0.00873	0.00854	0.00824	0.00786	0.00730	0.00685	0.00619	0.00553	0.00474	0.00394	0.00304
120	48.8	0.01006	0.01004	0.00998	0.00979	0.00949	0.00911	0.00855	0.00810	0.00744	0.00678	0.00599	0.00519	0.00429
125	51.6	0.01113	0.01111	0.01105	0.01086	0.01056	0.01018	0.00962	0.00917	0.00851	0.00785	0.00706	0.00625	0.00536
130	54.4	0.01238	0.01236	0.01230	0.01211	0.01181	0.01143	0.01087	0.01042	0.00976	0.00910	0.00831	0.00751	0.00661
135	57.2	0.01370	0.01368	0.01362	0.01342	0.01313	0.01275	0.01219	0.01174	0.01108	0.01042	0.00963	0.00883	0.00793
140	60	0.01503	0.01501	0.01495	0.01476	0.01446	0.01408	0.01352	0.01307	0.01241	0.01175	0.01096	0.01016	0.00926
145	62.7	0.01645	0.01643	0.01637	0.01618	0.01588	0.01550	0.01494	0.01449	0.01383	0.01317	0.01238	0.01158	0.01068
150	65.5	0.01787	0.01787	0.01779	0.01760	0.01730	0.01692	0.01636	0.01591	0.01525	0.01459	0.01330	0.01300	0.01210
155	68.3	0.01939	0.01937	0.01931	0.01912	0.01882	0.01844	0.01788	0.01743	0.01677	0.01611	0.01532	0.01452	0.01362
160	71.1	0.02094	0.02092	0.02086	0.02067	0.02037	0.01999	0.01943	0.01877	0.01811	0.01732	0.01652	0.01572	0.01482
165	73.8	0.02254	0.02252	0.02246	0.02227	0.02197	0.02159	0.02103	0.02058	0.01992	0.01926	0.01847	0.01767	0.01677
170	76.6	0.02420	0.02418	0.02412	0.02393	0.02363	0.02325	0.02269	0.02224	0.02158	0.02092	0.02013	0.01933	0.01843
175	79.4	0.02590	0.02588	0.02582	0.02563	0.02533	0.02495	0.02439	0.02394	0.02328	0.02262	0.02183	0.02103	0.02013
180	82.2	0.02765	0.02763	0.02757	0.02738	0.02708	0.02670	0.02614	0.02569	0.02503	0.02437	0.02358	0.02278	0.02188
185	85	0.02943	0.02941	0.02935	0.02916	0.02886	0.02848	0.02792	0.02747	0.02681	0.02615	0.02536	0.02456	0.02366
190	87.7	0.03129	0.03127	0.03121	0.03102	0.03072	0.03034	0.02978	0.02933	0.02867	0.02801	0.02722	0.02642	0.02552
195	90.5	0.03316	0.03314	0.0330	0.03289	0.03259	0.03221	0.03165	0.03120	0.03054	0.02988	0.02909	0.02829	0.02739
200	93.3	0.03512	0.03510	0.03504	0.03485	0.03455	0.03417	0.03361	0.03316	0.03250	0.03184	0.03105	0.03025	0.02935
205	96.1	0.03709	0.03707	0.03701	0.03682	0.03652	0.03614	0.03558	0.03513	0.03447	0.03381	0.03302	0.03222	0.03132
210	98.8	0.03913	0.03911	0.03905	0.03885	0.03856	0.03818	0.03762	0.03717	0.03651	0.03585	0.03506	0.03426	0.03336
215	101.6	0.04122	0.04120	0.04114	0.04095	0.04065	0.04027	0.03971	0.03926	0.03860	0.03794	0.03715	0.03635	0.03545
220	104.4	0.04337	0.04335	0.04329	0.04310	0.04280	0.04242	0.04186	0.04141	0.04075	0.04009	0.03930	0.03850	0.03760
225	107.2	0.04551	0.04549	0.04543	0.04524	0.04494	0.04456	0.04400	0.04355	0.04289	0.04223	0.04144	0.04064	0.03974
230	110	0.04764	0.04762	0.04756	0.04737	0.04707	0.04669	0.04613	0.04568	0.04502	0.04436	0.04357	0.04277	0.04187
235	111.7	0.04993	0.04991	0.04985	0.04966	0.04936	0.04898	0.04842	0.04797	0.04731	0.04665	0.04586	0.04506	0.04416
240	115	0.05222	0.05220	0.05214	0.05195	0.05165	0.05127	0.05071	0.05026	0.04960	0.04894	0.04815	0.04735	0.04645
245	118.3	0.05451	0.05449	0.05443	0.05424	0.05394	0.05356	0.05300	0.05255	0.05189	0.05123	0.05044	0.04964	0.04874

SYSTEM VOLUME CALCULATION



Add the total pipe fluid volume in gallons (from table 1) to the total fluid volume of all system components in gallons. Boilers, heat exchangers, etc.:

TABLE 1
Pipe volume in gallons per foot

PIPE DIAMETER	½"	¾"	1"	1 ¼"	1 ½"	2"	2 ½"
Steel pipe (Sch. 40)	0.0157	0.0277	0.0449	0.0779	0.106	0.174	0.249
Copper tube	0.0121	0.0251	0.0429	0.0653	0.0924	0.161	0.248

PIPE DIAMETER	3"	4"	5"	6"	8"	10"	12"
Steel pipe (Sch. 40)	0.384	0.66	1.04	1.51	2.61	4.11	5.82
Copper tube	0.354	0.622	0.971	1.39	2.43	3.78	5.46

TABLE 2
Plain steel tank volume in gallons from tank dimensions

Diameter (in)	Length (in)	Volume (gallons)	Gallons per each additional inch
12	33	15	0.49
14	48	30	0.67
16	72	60	0.87
20	78	100	1.36
24	72	135	1.96
30	84	240	3.06
36	93	400	4.41
42	96	525	6.00

TABLE 3
Water content in heat exchangers

Shell diameter (in)	Gallons per foot for shell length	
	In shell	In tubes
4	0.425	0.225
6	1.00	0.50
8	1.85	1.00
10	2.40	1.20
12	4.00	2.20
14	5.00	2.50
16	6.50	3.50
18	8.00	4.50
20	10.00	5.50
24	15.00	7.50

ACCEPTANCE FACTORS TABLE



Use gauge pressure

(P₀) Maximum operating pressure		P_f - Minimum operating pressure at tank (psig)/kPa											
psig	kPa	5 34.5	10 68.9	12 82.7	15 103.4	20 137.9	25 172.4	30 206.8	35 241.3	40 275.8	45 310.3	50 344.7	55 379.2
10	68.9	0.202	-										
12	82.7	0.262	0.075	-									
15	103.4	0.337	0.168	0.101	-								
20	137.9	0.432	0.288	0.231	0.144	-							
25	172.4	0.504	0.378	0.328	0.252	0.126							
27	186.1	0.527	0.408	0.360	0.288	0.168	-						
30	206.8	0.560	0.447	0.403	0.336	0.224	0.112	-					
35	241.3	0.604	0.503	0.463	0.403	0.302	0.202	0.101	-				
40	275.8	0.640	0.548	0.512	0.457	0.366	0.274	0.183	0.091	-			
45	310.3	0.670	0.586	0.553	0.503	0.419	0.335	0.251	0.168	0.084	-		
50	344.7	0.696	0.618	0.587	0.541	0.464	0.386	0.309	0.232	0.155	0.078	-	
55	379.2	0.717	0.646	0.617	0.574	0.502	0.430	0.359	0.287	0.215	0.144	0.072	-
60	413.7	0.736	0.669	0.643	0.602	0.536	0.469	0.402	0.335	0.268	0.201	0.134	0.067
65	448.2	0.753	0.690	0.665	0.627	0.565	0.502	0.439	0.376	0.314	0.251	0.188	0.125
70	482.6	0.767	0.708	0.685	0.649	0.590	0.531	0.472	0.413	0.354	0.295	0.236	0.177
75	517.1	0.780	0.725	0.702	0.669	0.613	0.558	0.502	0.446	0.390	0.333	0.279	0.223
80	551.6	0.792	0.739	0.718	0.686	0.634	0.581	0.528	0.475	0.422	0.370	0.317	0.264
85	586.1	0.802	0.752	0.732	0.702	0.652	0.602	0.552	0.502	0.451	0.401	0.351	0.301
90	620.5	0.812	0.764	0.745	0.716	0.669	0.621	0.573	0.525	0.478	0.430	0.382	0.335
95	655.0	0.820	0.775	0.757	0.729	0.684	0.638	0.593	0.547	0.501	0.456	0.410	0.365
100	689.5	0.828	0.785	0.767	0.741	0.698	0.654	0.610	0.567	0.523	0.479	0.436	0.392
105	723.9	0.835	0.794	0.777	0.752	0.710	0.668	0.626	0.585	0.543	0.501	0.459	0.418
110	758.4	0.842	0.802	0.786	0.762	0.723	0.682	0.642	0.601	0.561	0.521	0.481	0.441
115	792.9	0.848	0.810	0.794	0.771	0.734	0.694	0.655	0.617	0.578	0.540	0.501	0.463
120	827.4	0.854	0.817	0.802	0.780	0.742	0.705	0.668	0.631	0.594	0.557	0.520	0.483
125	861.8	0.859	0.823	0.809	0.787	0.752	0.716	0.680	0.644	0.608	0.573	0.537	0.501
130	896.3	0.864	0.829	0.815	0.795	0.760	0.726	0.691	0.657	0.622	0.586	0.553	0.519
135	930.8	0.868	0.835	0.822	0.802	0.768	0.735	0.701	0.668	0.635	0.601	0.563	0.534
140	965.3	0.873	0.840	0.827	0.808	0.776	0.743	0.711	0.679	0.647	0.614	0.582	0.550
145	999.7	0.877	0.845	0.833	0.814	0.783	0.751	0.720	0.689	0.658	0.626	0.595	0.564
150	1034.2	0.880	0.850	0.838	0.820	0.789	0.759	0.729	0.699	0.668	0.638	0.608	0.577
155	1068.7	0.884	0.854	0.843	0.825	0.795	0.766	0.736	0.707	0.677	0.648	0.618	0.589
160	1103.2	0.887	0.859	0.847	0.830	0.801	0.773	0.744	0.716	0.687	0.658	0.630	0.601
165	1137.6	0.890	0.863	0.851	0.835	0.807	0.779	0.751	0.724	0.696	0.668	0.640	0.612
170	1172.1	0.893	0.866	0.855	0.839	0.812	0.785	0.758	0.731	0.704	0.677	0.649	0.622
175	1206.6	0.896	0.870	0.859	0.843	0.817	0.791	0.764	0.738	0.711	0.685	0.659	0.632
180	1241.1	0.899	0.873	0.863	0.847	0.822	0.796	0.770	0.745	0.719	0.693	0.668	0.642
185	1275.5	0.901	0.876	0.866	0.851	0.826	0.801	0.776	0.751	0.726	0.701	0.676	0.651
190	1310.0	0.904	0.879	0.870	0.855	0.831	0.806	0.782	0.757	0.733	0.709	0.684	0.660
195	1344.5	0.906	0.882	0.873	0.858	0.835	0.811	0.787	0.763	0.739	0.716	0.692	0.668
200	1379.0	0.908	0.885	0.876	0.862	0.838	0.815	0.792	0.768	0.745	0.722	0.699	0.675
205	1413.4	0.910	0.888	0.878	0.865	0.842	0.819	0.796	0.774	0.751	0.728	0.705	0.682
210	1447.9	0.912	0.890	0.881	0.868	0.845	0.823	0.801	0.779	0.756	0.734	0.712	0.689
215	1482.4	0.914	0.892	0.884	0.871	0.849	0.827	0.805	0.783	0.762	0.740	0.718	0.696
220	1516.8	0.916	0.895	0.886	0.873	0.852	0.831	0.810	0.788	0.767	0.746	0.724	0.703
225	1551.3	0.918	0.897	0.889	0.876	0.855	0.834	0.813	0.792	0.772	0.751	0.730	0.709
230	1585.8	0.919	0.899	0.891	0.879	0.858	0.838	0.817	0.797	0.777	0.756	0.736	0.715
235	1620.3	0.921	0.901	0.893	0.881	0.861	0.841	0.821	0.801	0.780	0.760	0.740	0.720
240	1654.7	0.923	0.903	0.895	0.883	0.864	0.844	0.825	0.805	0.785	0.766	0.746	0.727
245	1689.2	0.924	0.905	0.897	0.886	0.866	0.847	0.828	0.808	0.789	0.770	0.751	0.731
250	1723.7	0.926	0.907	0.899	0.888	0.869	0.850	0.831	0.812	0.793	0.774	0.755	0.737

ACCEPTANCE FACTORS TABLE



Use gauge pressure

(P₀) Maximum operating pressure		P_f - Minimum operating pressure at tank (psig)/kPa											
psig	kPa	60 413.7	65 448.2	70 482.6	75 517.1	80 551.6	85 586.1	90 620.5	95 655.0	100 689.5	105 723.9	110 758.4	115 792.9
60	413.7	-											
65	448.2	0.062	-										
70	482.6	0.118	0.059	-									
75	517.1	0.167	0.111	0.056	-								
80	551.6	0.211	0.158	0.106	0.053	-							
85	586.1	0.251	0.201	0.151	0.101	0.050	-						
90	620.5	0.287	0.239	0.191	0.143	0.096	0.048	-					
95	655.0	0.319	0.273	0.228	0.182	0.137	0.091	0.045	-				
100	689.5	0.347	0.305	0.261	0.218	0.174	0.131	0.087	0.043	-			
105	723.9	0.376	0.334	0.292	0.250	0.208	0.167	0.125	0.083	0.041	-		
110	758.4	0.401	0.361	0.321	0.281	0.241	0.200	0.160	0.120	0.080	0.040	-	
115	792.9	0.424	0.386	0.347	0.309	0.270	0.232	0.193	0.155	0.116	0.007	0.039	-
120	827.4	0.446	0.408	0.371	0.334	0.297	0.260	0.223	0.186	0.149	0.111	0.074	0.037
125	861.8	0.465	0.429	0.394	0.358	0.322	0.286	0.250	0.215	0.179	0.143	0.107	0.071
130	896.3	0.484	0.450	0.415	0.381	0.346	0.312	0.277	0.243	0.208	0.173	0.138	0.104
135	930.8	0.501	0.468	0.439	0.401	0.367	0.334	0.301	0.267	0.234	0.200	0.167	0.134
140	965.3	0.517	0.485	0.453	0.420	0.388	0.356	0.324	0.291	0.259	0.226	0.194	0.162
145	999.7	0.532	0.501	0.470	0.438	0.407	0.376	0.344	0.313	0.282	0.250	0.219	0.188
150	1034.2	0.547	0.517	0.486	0.456	0.426	0.396	0.365	0.335	0.305	0.273	0.243	0.213
155	1068.7	0.559	0.530	0.500	0.471	0.441	0.412	0.382	0.353	0.323	0.295	0.265	0.236
160	1103.2	0.573	0.544	0.515	0.487	0.458	0.430	0.401	0.372	0.344	0.315	0.286	0.258
165	1137.6	0.585	0.557	0.529	0.501	0.473	0.446	0.418	0.390	0.362	0.334	0.306	0.278
170	1172.1	0.595	0.568	0.541	0.514	0.487	0.460	0.433	0.406	0.378	0.352	0.325	0.298
175	1206.6	0.606	0.579	0.553	0.527	0.500	0.474	0.447	0.421	0.395	0.369	0.343	0.316
180	1241.1	0.616	0.590	0.565	0.539	0.513	0.488	0.462	0.436	0.411	0.385	0.360	0.334
185	1275.5	0.626	0.601	0.576	0.551	0.526	0.501	0.476	0.451	0.426	0.401	0.376	0.351
190	1310.0	0.635	0.611	0.587	0.562	0.538	0.513	0.489	0.465	0.440	0.415	0.391	0.366
195	1344.5	0.644	0.620	0.597	0.573	0.549	0.525	0.501	0.478	0.454	0.429	0.405	0.381
200	1379.0	0.652	0.629	0.605	0.582	0.559	0.535	0.512	0.489	0.466	0.443	0.419	0.396
205	1413.4	0.660	0.637	0.614	0.591	0.568	0.546	0.523	0.450	0.477	0.455	0.432	0.410
210	1447.9	0.667	0.645	0.622	0.600	0.578	0.556	0.533	0.510	0.489	0.467	0.445	0.423
215	1482.4	0.674	0.653	0.631	0.609	0.587	0.565	0.544	0.522	0.500	0.479	0.457	0.435
220	1516.8	0.682	0.660	0.639	0.618	0.597	0.575	0.554	0.533	0.511	0.490	0.469	0.447
225	1551.3	0.688	0.667	0.646	0.625	0.604	0.583	0.563	0.542	0.521	0.501	0.478	0.459
230	1585.8	0.695	0.675	0.654	0.634	0.613	0.593	0.573	0.552	0.532	0.511	0.490	0.470
235	1620.3	0.700	0.680	0.660	0.640	0.620	0.600	0.579	0.559	0.539	0.521	0.501	0.481
240	1654.7	0.707	0.687	0.668	0.648	0.629	0.609	0.589	0.570	0.550	0.530	0.510	0.491
245	1689.2	0.712	0.693	0.673	0.654	0.635	0.615	0.596	0.577	0.558	0.539	0.520	0.501
250	1723.7	0.718	0.699	0.680	0.661	0.642	0.623	0.604	0.585	0.566	0.548	0.529	0.510

$$\text{Acceptance Factor} = 1 - \frac{P_f}{P_0}$$

P_f = minimum absolute pressure, P_0 = maximum absolute pressure